Modeling operating modes for the MONJU nuclear power plant

LIND Morten¹, YOSHIKAWA Hidekazu², JØRGENSEN Sten Bay³, and YANG Ming²

1. Dept. Electrical Engineering, Technical University of Denmark, Kgs. Lyngby, Denmark (mli@elektro.dtu.dk)

Visiting Professor at College of Nuclear Science and Engineering, Harbin Engineering University, Harbin, China

2. College of Nuclear Science and Technology, Harbin Engineering University, Harbin, China

3. Dept. Chemical and Biochemical Engineering, Technical University of Denmark, Kgs. Lyngby, Denmark

Abstract: The specification of supervision and control tasks in complex processes requires definition of plant states on various levels of abstraction related to plant operation in start-up, normal operation and shut-down. Modes of plant operation are often specified in relation to a plant decomposition into subsystems or components or defined in relation to phases of the plant process. Multilevel Flow Modeling (MFM) is a methodology for representing goals and functions of complex process plants on multiple levels of means-end abstraction and is based on conceptual distinctions between purposes or goals of the process plant, its function and its structural elements. The paper explains how the means-end concepts of MFM can be used to provide formalized definitions of plant operation modes. The paper will introduce the mode types defined by MFM and show how selected operation modes can be represented for the Japanese fast breeder reactor plant MONJU. **Keyword:** nuclear power plants; Multilevel Flow Modeling; operating modes; knowledge representation

1 Introduction

The specification of supervision and control tasks in complex processes requires definition of plant states on various levels of abstraction related to plant operation in start-up, normal operation and shut-down. Modes of plant operation are often specified informally in relation to a plant decomposition into subsystems or components or defined in relation to phases of the process referring to plant functions.

Multilevel Flow Modeling (MFM) is a methodology for representing goals and functions of complex process plants on multiple levels of means-end abstraction and is based on conceptual distinctions between purposes or goals of the process plant, its function and its structural elements ^[1, 2]. At present MFM offers a very rich conceptual framework for representing goals, functions and plant structure and their relations and supports causal reasoning and reasoning about control actions ^[3, 4]. The paper will show that the means-end concepts of MFM can be used to formally define plant operation modes. The paper will introduce the mode types defined by MFM and describe how they relate to operation modes as usually defined in control engineering. The concepts will be demonstrated by modeling selected operation

modes for the Japanese fast breeder reactor plant MONJU.

In the following we will first introduce the MONJU nuclear power plant and describe the operation modes which are defined for plant start-up. Then we will give a short introduction to MFM and the modes types which can be derived from the means-end concepts of MFM. Finally we will show how MFM can be used to represent two selected operating modes of the MONJU reactor.

2 The Monju nuclear power plant

The MONJU nuclear power plant (Fig. 1) has a moderate electrical output of 280 MWe at full power but the plant configuration is rather complex in comparison with a conventional light water reactor. The reactor fuel is mixed oxide pellets with stainless steel cladding, and the reactor coolant is liquid sodium. The plant is composed by three different loops. The reactor power generated in the core is transferred by sodium coolant in the primary loop. The conveyed heat in the primary loop is then transferred to a sodium coolant in the secondary loop by an intermediate heat exchanger. The heat conveyed by the secondary sodium coolant is then transferred to the water coolant in the ternary loop by a rather complex configuration of water passage route including an evaporator, steam separator, super-heater, turbine, condenser, as well as air ventilation paths and many bypass route for the steam by the manipulation of many valves. The MONJU plant had stopped operation since December 5, 1995 due to a sodium leak accident until its restart in May 6, 2010.



Fig. 1 MONJU plant overview.



Fig. 2 Main flow paths and control systems for MONJU.

However, soon after restart it has been out of service for two years due to troubles with the fuel transfer machine after reactor shutdown for refueling.

2.1 Control systems of the MONJU FBR

The main flow paths and the control system of the MONJU FBR (Fig. 2) are more complex than for a light water reactor due to the many loops, components, pipes and valves, etc. and many feedback control systems. Details of the control system of the MONJU plant are described by Takahashi and Tamayama ^[5]. Objectives of the major control systems are shown in Table 1.

2.2 Overall Operation modes

The MONJU plant is operated in two overall modes A and B covering plant operation control from start-up

until full power.

- A. Operation control from reactor shutdown until generator is synchronized with the electric grid (40 % of full power)
- B. Operation control from 45% reactor power (40% of full power) until 100% power

The two overall operating modes A and B are decomposed into 6 sub-modes as shown in Fig. 3. The plant start-up includes a stepwise transition between these sub modes as indicated by the directed arrows. The sub modes will be explained below.

2.2.1 Operating Mode A

Mode A covers the transitions in operations from reactor shut down until the generator is synchronized

	·····	
Control System	Control targets	Objective
Power demand master	Plant power level	Set plant power level signal within power change restriction
	signal	
Reactor power control	Fine control rod	Create FCRD control signal to meet power demand within
System	movement	reactor outlet temperature limit
		Drive FCRD
Primary main coolant	Primary sodium	Set flow rate to meet power demand
flow control system	flow rate	
Secondary main coolant	Secondary sodium	Set flow rate to meet power demand
flow control system	flow rate	
Feed water flow	-EV outlet steam	Maintain degree of super heat of EV outlet steam temperature
Control system	temperature setting	
	-DP between feed	
	water adjust valve	
Main steam temperature	SH outlet steam	Maintain preset value of main steam temperature
Control system	temperature	
Main Steam Pressure	Main steam	Maintain main steam pressure
Control System	pressure	

 Table 1 Summary of major control systems in MONJU



Fig. 3 Modes of the MONJU Plant startup.

with the electric grid at 40 % of full power. Table 2



Table 2 Water and steam flow paths in mode A

depicts the changes in water and stream flow paths during the transitions in mode A. At the beginning there is no water or steam in the steam generator and turbine.

- 1. Start-up main pump of primary sodium loop, main pump of secondary sodium loop, condenser pump of feed water loop and start-up feed water pump. Their flow rate values are equivalent to those of 40% full power.
- 2. Then start nuclear heating by control rod extraction.
- The plant power will be increased gradually to 40 % of full power state by the operation control of water/steam loop

The operation of the water/steam loop is different from the sodium loops by the following reasons:

- Phase change of single liquid water, two phase, and saturated steam.
- Unlike the piping in the sodium loops, there are no pre-heating equipment for the water/steam piping system
- Since no wet steam is allowed to enter the super heater, super heater operation should be started after super heated steam can be generated in the evaporator



Table 3 Water and steam flow paths in mode B

The three main stages of start-up control in mode A are as follows;

- From water blow, warming up until feed water passage into evaporator to start evaporator feed water flow rate control and outlet steam pressure control of steam/water separator
- 2. Start super heater bypass operation to proceed with turbine start up until super heated steam generation by evaporator to be led to the super heater.
- 3. From establishing generator power connection to grid until automatic plant control by power demand master

2.2.3 Mode B

Mode B covers the transitions in operations from 45% reactor power (40 % of full power) until 100 % of full power. Table 3 depicts the changes in water and stream flow paths during the transitions in mode B. The operations in mode B can be explained as follows:

- 1. When reactor power reaches 45%, the electric power output becomes 40%,
- 2. From this stage the plant control moves to cascade control mode where individual sub control systems will be controlled by the demand signals issued by power demand master.

The operation modes for MONJU have not been defined by basic scientific principles but made by trial and error by computer simulation of the plant behavior to comply with control requirements. Validation should be made by operational tests. In the following we will show that Multilevel Flow Modeling can be used to provide formalized representations of the MONJU operation modes based on fundamental principles. A formalized representation of operation modes can be used for the design of systems for supervisory control and risk monitoring. The ability to represent operation modes in separate MFM models is important for the development of MFM based risk monitoring and diagnosis functions which can cover several operation modes [3, 6].

3 Multilevel Flow Modeling

MFM belongs to a branch of AI research called qualitative reasoning. The purpose of this research is to represent and reason about qualitative knowledge of physical systems. The MFM modeling language realizes these aims within the general domain of industrial processes and their automation systems. A particular challenge addressed by MFM is to offer modeling and reasoning techniques that can handle the complexity of large scale dynamic processes like *e.g.* the MONJU plant.

MFM represent goals and functions of process plants as interacting flows of material, energy and information. Concepts of means-end and whole-part decomposition and aggregation play a foundational role in MFM. These concepts enable humans to cope with complexity because they facilitate reasoning on different levels of abstraction. The power of means-end and whole-part concepts in dealing with complexity has roots in natural language. But natural language is not efficient for representing and reasoning about means-end and whole-part abstractions of complex physical artifacts. MFM development draws on insights from the semantic structure of natural language but is designed as an artificial diagrammatic language which can serve modeling needs of complex engineering domains. MFM concepts and their graphic representations are shown in Fig. 4. A detailed introduction to MFM and comprehensive descriptions of modeling examples are presented elsewhere ^[1, 2]. An MFM model of the MONJU FBR reactor considered here is explained in detail in Lind *et. al.*^[7].

Functions							
Mass and Energy Flow					Control		
source t	ransport	stora	ge conv	ersion	separation	steer	trip d
sink barrier balance distribution regulate suppres					suppress		
Relations							
objective	Influ	ence		Means	end	Cor	ntrol
function structure	influencer	participant	maintain produce	suppress destroy ──────────	producer- product mediate	enable	actuate

Fig. 4 MFM concepts and symbols.

The MFM concepts as depicted in Fig. 4 can be used to build models representing plant goals and functions. Recent extensions of MFM define additional concepts to represent relations between function and structure ^[8]. A relation between function and structure is actually composed of two relations and a role. A role is associated with a function and provides an abstract representation of a structure by its contribution to a function. For example the transport function performed by a pump is associated with an agent role

which represents the contribution of the pump to transport function. The transport function would also include an object role representing the contribution of the fluid transported. A relation between function and structure accordingly involves a role and an association relation and a realization relation. The role concept is important for definition of some of the mode types in MFM but will be ignored in the modeling of the MONJU operation modes presented later.

3.1 Modes in Multilevel Flow Modeling

The concept of mode is used in a variety of ways within engineering. We speak for example about control modes and modes of operation. The operating modes of the MONJU reactor described above define different stages of the startup which either have different objectives or different physical plant configurations or different control strategies. However, distinctions between different modes types are not made. Distinctions are important for the formalization of control actions involved in mode transitions. The concept of mode is also used in human factors to define a special category of human error where an operator is not aware of the current "mode" of automation. This mode problem has been the cause of serious accidents because the operator made decisions and interacted with the automation without knowing that the automation was in a different state than expected. In order to avoid such error it is mandatory to design the human machine interface so that that the operational state or mode of the automation system is transparent. Specification of modes is also important for the engineer designing the control logic and algorithms.

However, the semantics of the mode concept is accordingly somewhat vague and also overlapping with other words like state and phase. In the following we will provide a definition of the mode concept and a distinction between mode types derived from Multilevel Flow Modeling which contributes to a clarification.

3.2 Some definitions

The Merriam-Webster dictionary defines a mode as "a particular way of something". This very abstract definition allows a variety of interpretations. Here we will define a mode as the ways a purpose (the something) is reached *i.e.* to different modes of action. More precisely, a mode is the means or the manner or the ways by which the purpose of a corresponding part of the control system is performed rightly as intended.

It follows from this definition that modes of a system can be specified in relation to a means-end modeling framework. We can therefore expect that the application of MFM which makes refined distinctions between different types of means and ends would contribute to a considerable clarification of the concept of mode. This is what is proposed below.

3.3 MFM mode types

The concept of mode refers accordingly to the means-end relation. Modes for a system are therefore distinguished by being the relations between a system purpose and the different alternative means, manner or ways by which it is reached. Since multiple means could be involved in reaching a purpose we will define a mode as a set of relations connecting an end with some means.

Multilevel Flow Modeling provides an extensive set of concepts for representing means-end relations in complex systems as seen in Fig. 4. The concept of purpose is not an explicit concept of MFM but rather seen as super-ordinate and including concepts of goal, objective, function and role which all have connotations relating to purposes. MFM includes the means-end relations shown in Fig. 4 and the relations between functions, role and structure. Each means-end relation has an interpretation in terms of mode as shown in Table 4. This leads to the modes types in Table 5.

Each of the mode interpretations in Table 4 leads to two complementary mode types as shown in Table 5. One type assumes that the end is given and specifies the alternative means (end to means). The other type assumes a given set of means and specifies the end which they achieve (means to end). Modes can also be defined in relation to the control relations shown in Fig. 4 but will not be discussed here. MFM models are by definition multilevel representations and the mode types defined above would in most practical cases produce hierarchical mode structures *i.e.* one mode may include a combinations of sub-modes of various types. As an example, an objective mode could include several function modes and each function in those modes may again include several role modes *etc*.

3.4 Mode transitions

The MFM mode types defined above can be used to characterize transitions during plant start-up or shut down. A transition could be between modes of same type e.g. between two function-objective modes when there is a transition between alternative function sets for the same objective. Often however, a transition is more complex and will involve changes in e.g. the structural configuration as well as the goal-function relations. For example a change in plant objectives may require changes in the functions required *i.e.* a selection between different alternative function-objective modes for the new objective and for each of the function in that mode a selection between different structure-function modes.

3.5 Usage of mode concept for systems analysis

The individual control modes of a control system for any plant or process systems are implemented into the system to meet with different operational purpose of the system.

The success of the control system will be attained by accumulation of sequential successes of individual control modes implemented in the system to run the system as intended way for a specified time span by the coordination of the system elements. Therefore, a sort of "semiotic representation" by MFM for "control mode" as discussed generally in $3.1 \sim 3.4$ can be utilized as the knowledge based tools for fault diagnosis, disturbance analysis, etc., by noticing "how", "why", and "by what way" the individual control modes will fail, as in an example study of such causal reasoning based on MFM.^[9]

On the other hand, the word "control mode" in this paper is fundamentally the same concept as "phased mission" in systems reliability analysis in general or in the area of probabilistic risk analysis (PRA) especially, where the reliability evaluation of an dynamical system is made by considering the phased

Tuble Trible met preutons of means end reactions				
Means-en	d relation	Interpretation in terms of mode		
goal	←objective	meeting an objective is a particular way to reach a goal (the purpose)		
objective	←function	performing a function is a particular way to achieve an objective (the purpose)		
function	←role	performing a role is a particular way of contributing to a function (the purpose)		
role	←structure	providing a structure is a particular way to realize a role (the purpose)		

Table 4 Mode interpretations of means-end relations

Table 5 Means-end relations in MFM and correspondir	g modes types
---	---------------

Means-end relation	Purpose	Mode type
goal \leftarrow objective	To reach the	Objective-goal mode (end to means)
	goal	A mode is here defined as the set of objectives which should be met to reach
		a given goal. Different sets of objectives could be defined each defining a
		mode.
		Goal-objective mode (means to end)
		A mode is here defined by a goal which can be reached by a set of given
		objectives. There could be several alternative goal-objective modes
		because a set of objectives could serve several alternative goals.
objective \leftarrow function	To reach the	Function-objective mode (end-to means)
(produce, maintain, destroy,	objective	A mode is here defined as a set of system functions used to realize a given
suppress)		objective. A mode would then be described the objective and a flow or
		control structure and there could be different alternative structures for the
		same objective each characterizing a particular process or control mode for
		the system.
		Objective-function mode (means to end)
		A mode is here defined by an objective which is served by a set of given
		functions. There could be several objective-function modes because
		different alternative objectives may be served by the same set of functions.
function \leftarrow role	To contribute to a	Role-Function mode (end to means)
(associate)	function	A mode is here defined by a set of roles which can be associated with a
		given function. Different alternative role sets could be possible for the same
		function. Each of these sets and the function would define a role-function
		mode.
		Function-Role mode (means to end)
		A mode is here defined by a set of functions which can be associated with
		a given role. There could be several function-role modes because different
		alternative set of functions may be associated with the same role.
Role \leftarrow structure	To realize a role	Structure-Role mode (end to means)
(realize)		A mode is here defined as a set of physical components which realize a
		given role. Different components for the same role are possible. Each set of
		components and the fole would define a mode. This mode concept is useful
		for distinguishing between different modes of pumping e.g. forced versus
		natural circulation. Role Structure mode (means to end)
		A mode is here defined by a set of roles which is realized by a since
		A mode is nere defined by a set of roles which is realized by a given
		component.

mission change as seen for this example by GO-FLOW methodology.^[10]

In the subsequent chapter **4**, the mode transitions of the MONJU plant start-up until full power operation will be described as an practical example to deal with complex combinations of mode changes in actual plant system.

4 Modeling of MONJU operation modes

In the following we will show that MFM can be used to represent two selected operating modes of the MONJU FBR plant as depicted in Tables 2 and 3. We will not cover all the operating modes as this would be outside the scope of the present paper. The two selected modes will be represented by MFM models. One of the modes is "the superheated generation mode (B)" for which an MFM model already has been presented in detail ^[7]. The model for this mode is shown in Fig. 5 and will briefly be explained in **4.1**. The other mode is "hot water warming (A)" which will be explained in more detail in **4.2**.

The two modes selected are distinguished in two ways because they have different flow path configurations *i.e.* different structure and they have different goal-function relations. The MFM models of the two modes selected makes explicit the rather complex changes in the overall system states between operating modes. The goal, function and their means-end relations represented in MFM enables explicit definitions of the feasible (or possible) operating modes not as specifications of a set of quantitative states but as conceptual structures.

4.1 MFM model of superheated generation mode

A detailed description of the MFM model for superheated generation mode is presented by Lind et. al. ^[7]. The reader can there find a comprehensive explanation of the model. The representations of goals and functions of the PHTS, SHTS and the ECS subsystems are indicated in Fig. 5. The model show the pumping functions (efs1, efs2, efs3) and the functions of the water steam cycle (mfs1 and efs4) and their interconnections by means-end relations. The functional levels are also related by control functions (cst1, cst2, cst3, cst4, cst5, cst6, cst7 and cst8). Note that the overall coordination functions in MONJU performed by the power demand master, the reactor power program, the reactor outlet sodium temperature program, the PHTS flow program, the STHTS flow program and the feed water flow program are not included in the MFM model Fig. 5. The transition from superheated generation mode to the "plant control by power demand master" would require extensions of the control functions in the MFM model.



Fig. 5 MFM for superheated generation mode (sub-mode of mode B).

4.2 MFM Model of hot water warming mode

An MFM model of the hot water warming mode is shown in Fig. 6. In order to explain the model it is instructive to make a comparison with the model of the superheated generation mode shown in Fig. 5. First of all it can be seen that the control structures cst1, cst2, cst3, cst5, cst6, cst7 and cst8 are not in the hot water warming mode. Likewise, energy flow structures efs1, efs2 and parts of the functions in Fig. 5 are absent in Fig. 6 because these functions are not relevant for the hot water warming mode since these are functions of the primary and secondary heat transfer systems. The PHTS and the SHTS heat transfer systems are not used in the hot water warming mode where the feed water is heated by an auxiliary boiler when it passes through the feed water heaters. The functions of the auxiliary boiler and the heaters are represented in Fig. 6 by sou31 and tra32.

Note also that some of the functions in structure mfs1 in Fig. 5 are missing in Fig. 6 because of the different flow paths. In the superheated generation mode energy is transferred by steam from the evaporator to the turbine. In Fig. 6 the corresponding energy transports are absent because no steam is transferred from the evaporator to the turbine in the hot water warming mode. It is seen that the MFM models makes it



Fig. 6 MFM of the hot water warming mode (sub-mode of mode A).

possible to distinguish quite clearly the essential features of the two operating modes.

5 Conclusions

This paper gives a short introduction to MFM, defines MFM mode types and describe how they relate to operation modes defined in control engineering. It is shown that the essential features of two selected operation modes for the Japanese fast breeder reactor plant MONJU can be clearly distinguished by their respective MFM models. The paper is the first discussing how MFM can be used for modeling operation modes. Further research will consider the visualization of mode types in MFM as well as for the formal way to represent for MFM mode transition.. The results presented are important for further development of MFM applications in automation design and for risk monitoring and diagnosis.

Acknowledgement

This study has been supported by the Chinese 111 project on Nuclear Power Safety and Simulation (b08047). The authors of this paper would like to express their gratitude to Mr. K. Tamayama and Mr. K. Okusa, FBR Plant Engineering Center, Japan Atomic Energy Agency, for their kind explanation on the control system of the Monju plant.

References

- LIND, M.: An Introduction to Multilevel Flow Modeling. International Journal of Nuclear Safety and Simulation. 2011, Vol 2(1): 22-32.
- [2] LIND, M.: Control functions in MFM. International Journal of Nuclear Safety and Simulation. 2011, Vol 2:132-139.
- [3] LIND, M.: Reasoning about causes and consequences in multilevel flow models. Proc. European Safety and Reliability Conference (ESREL) 2011 Annual Conference, 2011. September 18-22, Troyes, France.
- [4] HEUSSEN, K. and LIND, M.: Representing Causality and Reasoning about controllability of Multi-level Flow Systems. Proc. IEEE International Conference on Systems, Man and Cybernetics. 2010, October 10.13, Istanbul Turkey.
- [5] TAKAHASHI, H. and TAMAYAMA, K.: Practice of Operation and Control of Fast Reactor, Chapter 5, Part I Practice of Nuclear Power Plant Control, In: Reactor Dynamic Control and Plant Control, Ed: by Yoshiaki Oka and Katsuo Suzuki, Ohmsha, Tokyo, Japan, 2008: 165-187 (In Japanese).

- [6] YOSHIKAWA, H., YANG, M., ZHIJIAN, Z., HASHIM, H., LIND, M., TAMAYAMA, K. and OKUSA, K.: Design concept of human interface system for risk monitoring for proactive trouble prevention. Proceedings of ICI2011. 2011, August, Daejon Korea.
- [7] LIND, M., YOSHIKAWA, H., JØRGENSEN, S. B., YANG, M., TAMAYAMA, K. and OKUSA, K.: Multilevel Flow Modeling of Monju Nuclear Power Plant. International Journal of Nuclear Safety and Simulation. 2011, Vol 2(3): 275-285.
- [8] LIND, M.: Knowledge Representation for Integrated Plant Operation and Maintenance. Proceedings of Seventh American Nuclear Society International Topical Meeting on Nuclear Plant Instrumentation, Control and

Human Machine Interface Technologies, 2010. November 7-11, Las Vegas USA.

- [9] GOFUKU, A.: Application of MFM to intelligent systems for supporting plant operators and designers: function-based inference technique, International Journal of Nuclear Safety and Simulation. 2011, Vol 2(3): 235-245.
- [10] MATSUOKA, T.: GO-FLOW methodology –Basic concept and integrated analysis framework for its applications-, International Journal of Nuclear Safety and Simulation. 2010, Vol 1(3): 198-206